


NOTE:
INTRUDER ALARM TYPE CABLE SHOULD BE USED FOR THE 2, 3 AND 4 CORE INTERLINK WIRING.

2 CORE CABLE
4 CORE CABLE
3 CORE CABLE

230V AC
OVERDOOR INDICATOR/PSU
RESET BUTTON
CEILING PULL SWITCH

DISABLED TOILET ALARM
TYPICAL CONNECTIONS

ISSUE	DATE	MODIFICATION	DRN.	CHD.	 <p>CAMEO SYSTEMS LTD 29 HAVILAND ROAD FERNDOWN INDUSTRIAL ESTATE WIMBORNE, DORSET, BH21 7SA ENGLAND</p>	DRAWN	DATE	SCALE	CHECKED	APPRD.
						K.C.B.	12.06.13			
					TEL (01202)892088					
					FAX (01202)861449					
					DRAWING NO. C51386					ISSUE A